

MAS Certified Green® Certificate of Compliance Low-Emitting Materials



Awarded to: **MPL COMPANY OF FAIRLAND, IN**
203 N. EDGERTON STREET; ZIP CODE 46126

Category: Construction Materials - Cultured Marble Wall Panels and Floor Pans
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *residential setting*
(modeled to 2 residential showers)

*Conforms With: Criteria of MAS Certified Green® Program *low-emitting materials*
LEED v4.1 ID+C, BD+C *low-emitting materials*
LEED TVOC Emissions at 14-days *0.5 mg/m³ or less*

Certified Products: ****Tub & Shower Surrounds:** *Textured Tile Pattern, Smooth Tile Pattern*, Classic Designs, Panels with Built-in Listellos, Specialty Molds, Interval Pattern, Vertical Pattern, Chevron (Flat/Glossy), Stars-Flat, Theory Pattern, Stitch, Bamboo, Metro, Herringbone, Beveled Vertical. Shower Pans:* *Corner, Center, Offset Left/Right, Specialty & ADA, Curved Front Left/Right, Trench Left/Right. Accessories:* *Foot Rests, Accessory Shelves, Soap Dishes, Specialty Molds, Trim Strips, Window Sills/Thresholds.* ** Products tested as representative exemplar of products listed above.

Test Date: January 30, 2023 Report No.: 2300008 Certificate No.: MAS2300008

Valid: January 2023 to January 2024



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>